

Reinspection fees as of 01/10/2023

- Farmington: 1st re-inspection is free. \$25 for each following re-inspection
- Cave Springs: Re-inspection fee is \$55
- Springdale: re-inspection fee is \$25
- Prairie Grove: re-inspection fee is \$25

November

Date Failed	Address	Inspection	Reason Failed	Re - Inspect Fee			Date Passed
				\$ 35.00	\$ 45.00	\$ 55.00	
11/8/2022	1078 Giulia	Final	Garage door keypad	1	1	1	11/15/2022
11/8/2022	1153 Giulia	Final	GFCI master bath	1	1	1	11/15/2022
11/8/2022	889 Fair Oaks	Final	Detector MBR, bar GFCI	1	1	1	11/18/2022
11/8/2022	890 Fair Oaks	Final	Garage GFCI	1	1	1	11/18/2022
11/8/2022	916 Fair Oaks	Final	LR light, GFCI RR, Pantry light	1	1	1	11/18/2022
11/14/2022	1010 Fair Oaks	Final	detector outside MBR	1	1	1	12/5/2022
11/14/2022	727 Woodplains	Final	Exhaust fans not vented out	1	1	1	11/18/2022
11/14/2022	739 Woodplains	Final	Heater not working	1	1	1	11/22/2022
11/14/2022	751 Woodplains	Final	outside faucets, heater, detector BR	1	1	1	11/22/2022
11/16/2022	1168 Giulia	Final	Exhaust fans not vented out	1	1	1	11/18/2022
11/16/2022	1169 Giulia	Final	exhaust fans, FP outlet, Rrtoilet, GFCI, whirlpool	1	1	1	11/18/2022
11/16/2022	1198 Giulia	Final	guest bath exhaust not vented outside	1	1	1	11/18/2022
11/17/2022	969 Arden	rough-in	air on water	1	1	1	11/22/2022
11/17/2022	1009 Arden	rough-in	air on water	1	1	1	11/22/2022
11/17/2022	1021 Arden	rough-in	air on water	1	1	1	11/22/2022
11/17/2022	1035 Arden	rough-in	air on water/gas	1	1	1	11/22/2022
11/17/2022	1049 Arden	rough-in	air on water/gas	1	1	1	11/22/2022
11/17/2022	1050 Arden	rough-in	air on water	1	1	1	11/29/2022
11/17/2022	889 Maple View	rough-in	air on water	1	1	1	11/29/2022
11/18/2022	915 Fair Oaks	Final	smoke outside NW BR, ladder to attic	1	1	1	11/28/2022
11/18/2022	1123 Giulia	Final	vents, heater, GFCI guest bathroom	1	1	1	11/29/2022
11/21/2022	1108 Giulia	Final	outlet/disposal switch not GFCI	1	1	1	11/29/2022
11/21/2022	1122 Giulia	Final	exhaust not vented outside, no smoke SE BR	1	1	1	11/29/2022
11/21/2022	1138 Giulia	Final	guest BR no light, Master BR Sitch upside down	1	1	1	11/29/2022
11/21/2022	1079 Giulia	Final	Outlet by condenser, Hout/Neu reversed	1	1	1	11/29/2022
11/21/2022	1063 Giulia	Final	microwave, ladder to attic	1	1	1	11/29/2022
11/21/2022	1017 Giulia	Final	ladder to attic, back porch light	1	1	1	11/29/2022
11/30/2022	1185 Giulia	Final	Lights Kitchen, Dining, M Bath, sm. garage door	1	1	1	11/29/2022

\$ 980.00 \$ 1,260.00 \$ 1,540.00

December

Date Failed	Address	Inspection	Reason Failed	Re - Inspect Fee			Date Paid
				\$	\$	\$	
12/2/2022	902 Pergola	Final	garage door, exhaust vents	1	1	1	
12/2/2022	1047 Giulia	Final	attic door/ladder	1	1	1	
12/2/2022	1062 Giulia	Final	hallway lights	1	1	1	
12/6/2022	1109 Giulia	Final	outside outlets, Ladder	1	1	1	
				\$	\$	\$	
				140.00	180.00	220.00	